

# CERTIFICATE OF NFPA 705: FIELD FLAME TESTING

Date of Testing: August 12, 2019

Location:   
LL11-4155 Sheppard Ave., East, Toronto

Material Tested: 600D Polyester with UV Coated – White Tent

Method of Testing: Field Flame Test for textiles and films in accordance with N.F.P.A code 705 flame test procedures. As per Fire Code, Section 2.3.2 Flame Resistance of Textiles.

Test Results: **The Test material MET OR PASSED MINIMUM REQUIREMENTS**

This result is valid as of date of testing only, and should be renewed every 2 years.  
If materials are washed or become wet, the material must be re-treated immediately.



T: 800-465-2082  
F: 877-259-9990  
225 Teddington Pl,  
Burlington, On L7L 6X6  
info@onsiteservicegroup.com  
www.onsiteservicegroup.com

